




Z9A-pHMS-1B

CHEMICAL pH NEUTRALIZATION SYSTEM DETAIL METHOD #1B

SPECIFICATION SHEET

TAG _____

Dimensional Data (inches and [mm]) are Subject to Manufacturing Tolerances and Change Without Notice



ENGINEERING SPECIFICATION: Z9A-pHMS-1B

pH Monitor System is manufactured by Zurn Industries. The system is complete with 1) a HDPE ___ gallon sampling tank with bolted, gasketed cover. 2) a pH probe assembly consisting of an immersion type electrode and mounting brackets constructed of Polypropylene. 3) A Nema rated pH control panel housing with an Audible/Visual alarm with push button silencing relax. Unit to include up to 10 feet of cable for hook up from junction box relay to pH control panel. Contractor shall install equipment and components, in accordance with manufacturer's recommendations.

REV. B	DATE: 11/30/10	C.N. NO. 120589
DWG. NO. 67283		PRODUCT NO. Z9A-pHMS-1B

*REGULARLY FURNISHED UNLESS OTHERWISE SPECIFIED